

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 288

Dated: 09/08/2025

It is certified that an inspection team headed by Amor Kumar, Assistant Engineer

(Name of Officers with designation) from P.H. Subdivision Araria PHED

inspected the Kosi National School, Lahtora, Araria

(Name & Address of the school) on 08/08/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 287 dated 08/08/2025

of DLWTL, P.H. Division Araria (PHED Lab) certified that the

Kosi National School, Lahtora, Araria (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till one year

Signature with Seal: 09/08/2025

Name

Designation

Name & Address of the Office / Department

To
KOSI NATIONAL SCHOOL
LAHTORA, ARARIA 854325
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Rana Abuzar
PRINCIPAL
Kosi National School
Araria, 854325

Kamil Abuzar
MANAGER
Kosi National School
Araria, 854325

Letter No:- 207

Date:- 08/08/2025

Government of Bihar
DISTRICT LEVEL WATER TESTING LABORATORY UNDER, PUBLIC HEALTH DIVISION ARARIA.
CHEMICAL AND BACTERIOLOGICAL REPORT OF DRINKING WATER SAMPLES

District Name:- Araria

Sample Collected By- Jeevan Kumar

Testing Date:08-08-2025

SL. No.	Location of Source	Parameters Examined(Test Result in ppm)													
		pH	TDS	Conductivity	Turbidity	Total Hardness	Calcium	Magnesium	Chloride	Total Alkalinity	Iron	Nitrate	Fluoride	Arsenic	Bacteria
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
1	Kosi National School, Lahtora, Araria	7.48	172	266	0.9	124	32	12	29	117	0.43	BDL	-	-	-
BIS 10500:2012 (second revision)	Desireable Limit	6.5-8.5	500	-	1.0	200	75	30	250	200	1.0	45	1.0	0.01	-Ve
	Permissible Limit in absence of alternate source	NR	2000	-	5.0	600	200	100	1000	600	NR	NR	1.5	NR	**

Note (i) BDL means below detection Limit (ii) NR means no relaxation

[Signature]
 08/08/2025
 Chemist (Research Assistant)
 P.H.Division,Araria

[Signature]
PRINCIPAL
 Kosi National School
 Araria, 854325

[Signature]
MANAGER
 Kosi National School
 Araria, 854325